



防爆合格证

证号: GYJ14.1436X

由 日本岛田电机株式会社

制造的产品:

(地址: 日本国东京都大田区仲池上2-29-6)

名称 Flame Proof Junction Box

型号规格 STH-a

防爆标志 Ex d II B T6 Gb

产品标准 /

图样编号 AA20740, AA20741, AA20742, AA20743, AA20744

经图样及技术文件的审查和样品检验, 确认上述产品符合 GB 3836.1-2010、GB 3836.2-2010 标准, 特颁发此证。

本证书有效期: 2014年11月26日至2019年11月25日

- 备注
1. 安全使用注意事项见使用说明书。
 2. 证书编号后缀“X”表明产品具有安全使用特殊条件: a. 涉及隔爆接合面的维修须联系产品制造商。
b. 产品隔爆接合面用特殊紧固件性能等级不低于A2-70。
 3. 型号规格说明: a代表产品尺寸, 可为1、3、5、6、7。
 4. 产品外壳防护等级: IP66。

站长

国家级仪器仪表防爆安全监督检验站

颁发日期二〇一四年十一月二十六日

本证书仅对与认可文件和样品一致的产品有效。

地址: 上海市漕宝路103号
邮编: 200233

网址: www.nepsi.org.cn
Email: info@nepsi.org.cn

电话: +86 21 64368180
传真: +86 21 64844580



EXPLOSION PROTECTION

CERTIFICATE OF CONFORMITY

Cert NO.GYJ14.1436X

This is to certify that the product

Flame Proof Junction Box

manufactured by SHIMADA ELECTRIC CO., LTD.

(Address:2-29-6, Nakaikegami Ota-ku, Tokyo, Japan)

which model is STH-a

Ex marking Ex d II B T6 Gb

product standard /

drawing number AA20740, AA20741, AA20742, AA20743, AA20744

has been inspected and certified by NEPSI, and that it conforms to GB 3836.1-2010,GB 3836.2-2010

This Approval shall remain in force until 2019.11.25

Remarks

- 1.Conditions for safe use are specified in the instructions.
- 2.Symbol "X" placed after the certification number denotes specific conditions of use:
a.Contact the original manufacturer for information on the dimensions of the flameproof joints. b.Property class of A2-70 or higher fasteners should be used.
- 3.Model designation: a stands for dimension-1, 3, 5, 6, 7.
- 4.Degrees of protection provided by enclosures: IP66.

Director



National Supervision and Inspection Centre for
Explosion Protection and Safety of Instrumentation

Issued Date 2014.11.26

This Certificate is valid for products compatible with the documents and samples approved by NEPSI.

103 Cao Bao Road
Shanghai 200233, China

<http://www.nepsi.org.cn>
Email: info@nepsi.org.cn

Tel: +86 21 64368180
Fax: +86 21 64844580