

防爆合格证

证号: GYJ14.1437X

由 日本岛田电机株式会社
(地址: 日本国东京都大田区仲池上2-29-6)
名称 Flame Proof Junction Box
型号规格 SXTB-a
防爆标志 Ex d IIC T6 Gb
产品标准 /
图样编号 AA20738, AA20739

制造的产品:

经图样及技术文件的审查和样品检验, 确认上述产品符合 GB 3836.1-2010、GB 3836.2-2010 标准, 特颁发此证。

本证书有效期: 2014年11月26日至2019年11月25日

- 备注
1. 安全使用注意事项见使用说明书。
 2. 证书编号后缀“X”表明产品具有安全使用特殊条件: 涉及隔爆接合面的维修须联系产品制造商。
 3. 型号规格说明: a代表产品尺寸, 可为04、06。
 4. 产品外壳防护等级: IP66。

站长



国家级仪器仪表防爆安全监督检验站


颁发日期二〇一四年十一月二十六日

本证书仅对与认可文件和样品一致的产品有效。

地址: 上海市漕宝路103号
邮编: 200233

网址: www.nepsi.org.cn
Email: info@nepsi.org.cn

电话: +86 21 64368180
传真: +86 21 64844580



EXPLOSION PROTECTION CERTIFICATE OF CONFORMITY

Cert NO.GYJ14.1437X

This is to certify that the product

Flame Proof Junction Box

manufactured by **SHIMADA ELECTRIC CO., LTD.**

(Address:2-29-6, Nakaikegami Ota-ku, Tokyo, Japan)

which model is **SXTB-a**

Ex marking **Ex d II C T6 Gb**

product standard /

drawing number **AA20738, AA20739**

has been inspected and certified by NEPSI, and that it conforms
to **GB 3836.1-2010, GB 3836.2-2010**

This Approval shall remain in force until **2019.11.25**

Remarks

- 1.Conditions for safe use are specified in the instructions.
- 2.Symbol "X" placed after the certification number denotes specific conditions of use:
Contact the original manufacturer for information on the dimensions of the flameproof joints.
- 3.Model designation: a stands for dimension-04, 06.
- 4.Degrees of protection provided by enclosures: IP66.

Director



**National Supervision and Inspection Centre for
Explosion Protection and Safety of Instrumentation**

Issued Date **2014.11.26**

This Certificate is valid for products compatible with the documents and samples approved by NEPSI.

103 Cao Bao Road
Shanghai 200233, China

<http://www.nepsi.org.cn>
Email: info@nepsi.org.cn

Tel: +86 21 64368180
Fax: +86 21 64844580