



防爆合格证

证号: GYJ16.1093X

由 日本岛田电机株式会社

制造的产品:

(地址: 日本国东京都大田区仲池上2-29-6)

名称 堵头

型号规格 EXBP-a

防爆标志 Ex d II C Gb (Thread form M, NPT)

Ex e II C Gb, Ex tD A21 IP66 (Thread form M, NPT, G)

产品标准 /

图样编号 GB60053

经图样及技术文件的审查和样品检验, 确认上述产品

符合 GB 3836.1-2010、GB 3836.2-2010、GB 3836.3-2010、
GB 12476.1-2013、GB 12476.5-2013 标准,

特颁发此证。

本证书有效期: 2016年2月29日至2021年2月28日

- 备注
1. 安全使用注意事项见使用说明书。
 2. 证书编号后缀“X”表明产品具有安全使用特殊条件: 涉及隔爆接合面的维修须联系产品制造商。
 3. 型号规格说明: a代表螺纹规格, 详见说明书。

站长

国家级仪器仪表防爆安全监督检验站

颁发日期二〇一六年二月二十九日

本证书仅对与认可文件和样品一致的产品有效。

地址: 上海市漕宝路103号
邮编: 200233

网址: www.nepsi.org.cn
Email: info@nepsi.org.cn

电话: +86 21 64368180
传真: +86 21 64844580



EXPLOSION PROTECTION CERTIFICATE OF CONFORMITY

Cert NO.GYJ16.1093X

This is to certify that the product

STOPPING PLUG

manufactured by SHIMADA ELECTRIC CO., LTD.

(Address:2-29-6, Nakaikegami Ota-ku, Tokyo, Japan)

which model is EXBP-**a**

Ex marking

Ex d II C Gb (Thread form M, NPT)

Ex e II C Gb, Ex tD A21 IP66 (Thread form M, NPT, G)

product standard /

drawing number GB60053

has been inspected and certified by NEPSI, and that it conforms

to GB 3836.1-2010,GB 3836.2-2010,GB 3836.3-2010,GB 12476.1-2013,
GB 12476.5-2013

This Approval shall remain in force until 2021.02.28

Remarks

- 1.Conditions for safe use are specified in the instructions.
- 2.Symbol "X" placed after the certification number denotes specific conditions of use: Contact the original manufacturer when repair work relates to the flamepath.
- 3.Model designation: **a** stands for thread form, refer to instruction manual.

Director



National Supervision and Inspection Centre for
Explosion Protection and Safety of Insirumentation

Issued Date 2016.02.29

This Certificate is valid for products compatible with the documents and samples approved by NEPSI.

103 Cao Bao Road
Shanghai 200233, China

<http://www.nepsi.org.cn>
Email: info@nepsi.org.cn

Tel: +86 21 64368180
Fax: +86 21 64844580