



防爆合格证

证号: GYJ21.1083X

由 日本岛田电机株式会社

制造的产品:

(地址: 日本国东京都大田区仲池上2-29-6)

名称 防爆堵头

型号规格 EXBP-

防爆标志 Ex d IIC Gb (Thread form M, NPT)
Ex e IIC Gb, Ex tD A21 IP66 (Thread form M, NPT, G)

产品标准 /

图样编号 GB60053

经图样及技术文件的审查和样品检验, 确认上述产品符合 GB 3836.1-2010、GB 3836.2-2010、GB 3836.3-2010、标准, GB 12476.1-2013、GB 12476.5-2013 特颁发此证。

本证书有效期: 2021年2月28日至2026年2月27日

备注 1. 安全使用注意事项见使用说明书。
2. 证书编号后缀“X”表明产品具有安全使用特殊条件: 涉及隔爆接合面的维修须联系产品制造商。
3. 型号规格说明: 代表螺纹规格, 详见说明书。

站长

国家级仪器仪表防爆安全监督检验站

颁发日期二〇二一年二月二十八日

本证书仅对与认可文件和样品一致的产品有效。

地址: 上海市漕宝路103号
邮编: 200233

网址: www.nepsi.org.cn
Email: info@nepsi.org.cn

电话: +86 21 64368180
传真: +86 21 64844580



EXPLOSION PROTECTION

CERTIFICATE OF CONFORMITY

Cert NO.GYJ21.1083X

This is to certify that the product

STOPPING PLUG

manufactured by **SHIMADA ELECTRIC CO., LTD.**

(Address:2-29-6, Nakaikagami Ota-ku, Tokyo, Japan)

which model is **EXBP-X**

Ex marking **Ex d IIC Gb (Thread form M, NPT)**
Ex e IIC Gb, Ex tD A21 IP66 (Thread form M, NPT, G)

product standard /

drawing number **GB60053**

has been inspected and certified by NEPSI, and that it conforms
to **GB 3836.1-2010,GB 3836.2-2010,GB 3836.3-2010,GB 12476.1-2013,**
GB 12476.5-2013

This Approval shall remain in force until **2026.02.27**

Remarks **1.Conditions for safe use are specified in the instructions.**
2.Symbol "X" placed after the certification number denotes specific conditions of
use: Contact the original manufacturer when repair work relates to the flamepath.
3.Model designation: X stands for thread form, refer to instruction manual.

Director


National Supervision and Inspection Centre for
Explosion Protection and Safety of Instrumentation

Issued Date **2021.02.28**

This Certificate is valid for products compatible with the documents and samples approved by NEPSI.